

File No.: J-13011/34/2008-IA. II(T) Government of India Ministry of Environment, Forest and Climate Change IA Division

The state of the s

Dated 23/09/2023



To,

Shri Vivek NaradShri Vivek Narad

MADHYA PRADESH POWER GENERATING CO. LIMITED (MPPGCL)

Block No.9, Shakti Bhawan, Rampur, Jabalpur, Jabalpur, JABALPUR, MADHYA PRADESH, Shakti

Bhawan, 482008

prgstps660@gmail.com

Subject:

Amendment in Environmental Clearance (EC) dated 27/06/2023 granted to the project under the provision of the EIA Notification 2006 and as amended thereof-regarding.

Sir/Madam,

This is in reference to your application submitted to MoEF&CC vide proposal number IA/MP/THE/434801/2023 dated 27/06/2023 for grant of an amendment in prior Environmental Clearance (EC) to the project under the provision of the EIA Notification 2006-and as amended thereof.

2. The particulars of the proposal are as below:

(i) EC Identification No. EC23A0601MP5704510A (ii) File No. J-13011/34/2008-IA. II(T)

(iii) Clearance Type Amendment in EC

(iv) Category A

(v) Schedule No./ Project Activity 1(d) Thermal Power Plants

(vi) Sector Thermal Projects

2x250 MW Thermal Power Plant at Satpura

(vii) Name of Project Thermal Power Station (STPS), Sarni – Extension

Units 10 & 11.

(viii) Location of Project (District, State) JABALPUR, MADHYA PRADESH

(ix) Issuing AuthorityMoEF&CC(x) EC Date23/08/2023

(xi) Applicability of General Conditions NO

(xiii) Status of implementation of the project

3. In view of the particulars given in the Para 1 above, the project proposal interalia including Form-1(Part A,

- B and C) were submitted to the MoEF&CC for an appraisal by the Expert Appraisal Committee EAC under the provision of EIA notification 2006 and its subsequent amendments.
- 4. The above-mentioned proposal has been considered by [Expert Appraisal Committee] (EAC) in the meeting held on 20/07/2023. The minutes of the meeting and all the project documents are available on PARIVESH portal which can be accessed from the PARIVESH portal by scanning the QR Code above.
- 5. The brief about the reasons for an amendment requested along with comparison table illustrating the details of amendments are annexed to this letter as **Annexure (1)**.
- 6. The EAC, in its meeting held on [meeting held on], based on information & clarifications provided by the project proponent and after detailed deliberations recommended the proposal for grant of amendment in Environment Clearance under the provision of EIA Notification, 2006 and as amended thereof.
- 7. The MoEF&CC has examined the proposal in accordance with the extant provisions of the Environment Impact Assessment (EIA) Notification, 2006 & further amendments thereto and based on the recommendations of the Expert Appraisal Committee hereby accords amendment in Environment Clearance dated 27/06/2023 for the instant proposal to M/s. Shri Vivek NaradShri Vivek Narad under the provisions of EIA Notification, 2006 and as amended thereof subject to compliance of EC conditions, general instructions issued vide EC letter dated and EC identification number IA/MP/THE/434801/2023 and following additional specific conditions as mentioned below:
- 8. This issues with the approval of the Competent Authority

Copy To

- 1. The Secretary, Ministry of Power, Shram Shakti Bhawan, Rafi Marg, New Delhi -110 001.
- 2. The Deputy Director General of Forests, Ministry of Environment, Forest and Climate Change, Integrated Regional Office, E-5, Kendriya Paryavaran Bhawan, E-5 Arera Colony, Link Road No.3, Ravishankar Nagar, Bhopal –462 016
- 3. The Secretary, Department of Environment, Government of Madhya Pradesh, Secretariat, Bhopal.
- 4. The Member Secretary, Central Pollution Control Board, Parivesh Bhawan, EastArjun Nagar, Delhi 110 032.
- 5. The Member Secretary, Madhya Pradesh State Pollution Control Board, Paryavaran Parisar, E-5, Arera Colony, Bhopal 462016.
- 6. Guard File

Annexure 1

Specific EC Conditions for (Thermal Power Plants)

1. Additional Condition

S. No	EC Conditions			
1.1	 24x7 online Continuous monitoring system for ambient air quality parameters SOx, NOx and PM shall be established with connected server to CPCB and SPCB. Other conditions of the EC letter dated 27.02.2009 and amendment letter dated 27.03.2015 shall remain unchanged. 			

Amendment Logs

Description	Reference	Existing	Proposed / Amendment	Reason
EC Condition	Condition no.3/(xvi) of EC no. J- 13011/34/2008- IA.II(T) dtd.27.02.2009 for 2x250 MW unit	Sulphur content in the liquid fuel will not exceed 0.5%.	Project proponent shall undertake resource depletion of HFO and no further purchase shall be made of HFO. PP shall use LDO as liquid fuel and Sulphur content shall not exceed 1.5%.	Due to the non availability of low sulphur oil from the oil companies
Condition	Condition no.3/(v) of Permission issued vide no. J-13012/5/2013-IA.II(T) dtd. 27.03.2015.	mechanism for an inbuilt continuous monitoring for radio activity and heavy metals in coal and fly ash (including bottom ash) shall be put in place.	Regular monitoring for radio activity and heavy metals in coal and fly ash (including bottom ash) shall be carried out on quarterly basis through 3rd party NABL accredited laboratories.	Radioactivity and heavy metal contents in coal, bottom ash, and fly ash are being analyzed through 3rd party NABL accredited laboratories.

